


NOTE:
DISTRIBUTION MAIN SHALL BE INSTALLED WITH A MINIMUM OF 5' OF COVER.

DRAFT

 <p>TOWN OF WAKEFIELD</p>	ENGINEERING DIVISION - WAKEFIELD PUBLIC WORKS		
	DESIGN AND CONSTRUCTION STANDARDS WATER MAIN TRENCH		
	SCALE: NTS	DETAIL #: W-03	DATE: MAY 22 2023